

STATE OF MONTANA DEPARTMENT OF LABOR AND INDUSTRY BUILDING CODES BUREAU
ELEVATOR SAFETY SECTION
TEST REPORT OF GOVERNORS, SAFETY DEVICES, OIL BUFFERS AND RELIEF VALVES

ALL TESTING SHALL BE PERFORMED BY LICENSED ELEVATOR PERSONEL

ANNUAL TRACTION , DRUM or RACK and PINION ELEVATOR TEST FORM

STATE ELEVATOR No. _____

Required by ARM 24.301.601 (d) Appendix N, Table N1 of ASME A17.1, 2004 Edition

Name of Building: _____ County: _____

Building Address _____
NUMBER STREET CITY ZIP CODE

Type of elevator being tested: Passenger () Freight () LULA () Dumbwaiter () Other: _____
Machine type: Traction () Drum () Rack and Pinion () Other: _____
Type of safety being tested: Broken rope () A: Instantaneous () B: Gradual () C: type A with oil buffers ()
Location of safety devices: Safety plank () Crosshead () Counterweight ()
Did all Stop, Broken rope, selector tape/cable ,Car top exit or compensation switches disable elevator as required? Yes () No ()
Material of guide rails: Car: Steel () Wood () Counterweight : Steel () Wood () NA ()
Type of governor: Flyball () Centrifugal () NA () Sealed before test : Yes () No () NA ()
Type and number of buffers: Car: Spring () Oil () NA () Other _____ Number _____
Counterweight buffers : Spring () Oil () NA () Other _____ Number _____
Did Final Limits operate in both directions ? Yes () No () NA () Did Normal Limits operate as required ? Yes () No ()
Did Firefighters' Emergency Operation Phase 1 and Phase 2 function as required ? Yes () No () NA ()
Was the door closing force less than 30 lbs. when tested between 1/3 and 2/3s of opening after stalling door? Yes () No () NA ()
Are the required governor, buffer and releasing carrier seals and tags affixed in accordance with the code ? Yes () No ()
Has this test been logged in the elevator maintenance log and is maintenance log up to date ? Yes () No ()

Tags CANNOT BE MARKED WITH MARKING PENS. TAGS CAN ONLY BE USED FOR ONE YEAR

PERIODIC TEST FOR GOVERNORS, SAFETIES AND OIL BUFFERS

Section 8.11.2.2 of ASME A17.1, 2004 Edition- REQUIRED EVERY 12 MONTHS

Cable leaving the safety drum: _____ inches. NA () Turns remaining on drum: _____ NA ()
Did governor jaws drop of its own weight when latch was released? Yes () No () NA ()
Did all parts of governor and safety perform the functions for which intended? Yes () No () NA ()
Did governor switch disable elevator ? Yes () No () NA ()
Did Safety operated switch disable elevator ? Yes () No ()
Did oil buffers return within 90 seconds and was oil level checked? Yes () No () NA ()

Have any changes been made since last year ? Yes () No () Are any Changes needed ? Yes () No ()

Company Name _____ Date _____

Sign Name _____ Print Name _____ State License No. _____

All lines Must Be Filled out with Each Test.. Send in within 10 days of completion of tests to
Building Codes Bureau Fax 406-481-2050 or Email buildingcodes@mt.gov
Effective Date 8/31/2018